

## Water Testing Results - Pine Creek Elementary

### Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result
Main Classroom Faucet	20160100-001CF	10/30/2020	0.594
Men's Bathroom Sink	20160100-002BF	10/30/2020	ND
Women's Bathroom Left Sink	20160100-003BF	10/30/2020	ND
Women's Bathroom Right Sink	20160100-004BF	3/22/2021	ND
Janitor's Sink	20160100-005SF	10/23/2021	13.9
<b>Teacherage</b>			
Kitchen Faucet	20160104-001KF	10/30/2020	2.95
Guest Bathroom	20160104-002BF	10/30/2020	3.07
Master Bath Left Sink	20160104-003BF	3/22/2021	15.4
Master Bath Right Sink	20160104-004BF	3/22/2021	18.7
Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing			
ND = Non Detect - Lead level is below the set detection limits			of <b>1</b> ppb