

# **UMPQUA Research Company**

626 NE Division St. - P.O. Box 609 Myrtle Creek, Oregon 97457 (541) 863-5201 Fax: (541) 863-6199

E-mail: Lab@URCmail.net Internet: http://ChemLab.cc ORELAP ID# OR100031

Project: No Project

Date Reported: 05/19/22

PO Box 888

Double O SD28

Hines, OR 97738

Project #: No Project

Date Received: 05/17/22 11:45

ANALYSIS REPORT

2051729

URC#

Sampled By:

Client Contact: Julie Opie

Method: EPA 200.8								Matrix: Drinking Water	
	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst Qualifier
2051729-01	Sample Location: Pump House								
Lead (‡)		1030	1.3	ppb	1.0	15	05/13/22 09:03	05/18/22	DST
2051729-02	Sample Location: Teacherage								
Lead (‡)		1030	ND	ppb	1.0	15	05/13/22 09:20	05/18/22	DST
2051729-03	Sample Location: Outside Faucet								
Lead (‡)		1030	ND	ppb	1.0	15	05/13/22 08:45	05/18/22	DST

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager

### **UMPQUA Research Company**

626 NE Division St. - P.O. Box 609 Myrtle Creek, Oregon 97457 (541) 863-5201 Fax: (541) 863-6199

E-mail: Lab@URCmail.net Internet: http://ChemLab.cc ORELAP ID# OR100031

## ANALYSIS REPORT URC # 2051729

#### **Qualifiers and Definitions**

DET Analyte DETECTED

ND Analyte NOT DETECTED at or above the MRL (minimum reporting limit)

NA Not Applicable NR Not Reported

dry Sample results reported on a dry weight basis

RPD Relative Percent Difference
MRL Minimum Reporting Limit
MDL Minimum Detection Limit
MCL Maximum Contamination Level
(‡) ORELAP Accredited Analyte

(~) Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager