

Box R Water Analysis Laboratory LLC
 567 NW 2nd St. Prineville, OR 97754
 Phone: (541)447-4911 Fax: (541)447-4917
 ORELAP # 100054

To be filled in by Person Submitting Sample:	
Public Water System <input checked="" type="checkbox"/>	Realty Transaction <input type="checkbox"/> N/A
PWS ID #: 41- 05010	Source ID: EP-A Source Name: Well
Public Water System or Property Owner: Pine Creek Elem. School.	
cb Harney ESD	
Address: 25 Fairview Heights Loop	
City, State, Zip: Burns OR 97720	
Sampled at: 79158 Pine Creek Rd Drewsey OR 97904	
Sampled By: Shannon Cross	
Date Collected: 12-16-2021	Time Collected: 0900
Sample Composition: <u>Raw</u> or Treated Water From Source or <u>Distribution</u> Single or Combined Sample	

To be completed by Laboratory:						
Date Received in Lab: 12-16-2021			Date Analyzed: 12-16-2021			
Lab Sample ID: X048593A			Sample Compositing in Lab: Y <u>N</u>			
Contaminant	Code	MCL mg/L	Analysis mg/L	LRL	Method	Analyst
Nitrate	1040	10.	0.387 mg/L	1.0 mg/L	SM4500 -NO3-D	SKM
Nitrate-Nitrite	1038	10.				
Nitrite	1041	10.				

Box R Water Analysis Laboratory reserves the right to reject any sample that does not meet proper sampling procedures, or does not have a completed chain of custody form.

H:\home\mc\meyer\reports\results.no3 rev 8/25/95

J⁴