

# Radon Testing Results -Early Childhood Center

## Action Level is 4.0 pCi/L

Site Name	Building Name	Room Description (per floor plan)	Kit serial #	Date Sampled	Type of test	Results (pCi/L)
Early Childhood Center	School Building	Lobby	9545603	2020-12-07	Detector Kit	2.9
Early Childhood Center	School Building	Office 4	9545607	2020-12-07	Detector Kit	2.1
Early Childhood Center	School Building	Office 3 B	9545612	2020-12-07	Blank	0.3
Early Childhood Center	School Building	Office 3	9545613	2020-12-07	Detector Kit	1.9
Early Childhood Center	School Building	Office 2	9545614	2020-12-07	Detector Kit	2.2
Early Childhood Center	School Building	Infant Toddler Room A	9545615	2020-12-07	Detector Kit	2.8
Early Childhood Center	School Building	Infant Toddler Room D	9545616	2020-12-07	Duplicate	2.7
Early Childhood Center	School Building	Office 1	9545621	2020-12-07	Detector Kit	1.2
Early Childhood Center	School Building	Great Start Classroom	9545623	2020-12-07	Detector Kit	2.7
Early Childhood Center	School Building	Head Start Classroom	9545624	2020-12-07	Detector Kit	2.2
Early Childhood Center	School Building	Lobby Office	9545628	2020-12-07	Detector Kit	2.6
Early Childhood Center	School Building	Head Start Classroom 5 D	9545629	2020-12-07	Duplicate	2.7
Early Childhood Center	School Building	Head Start Classroom 5 A	9545630	2020-12-07	Detector Kit	2.8
Early Childhood Center	School Building	Home Based Classroom	9545631	2020-12-07	Detector Kit	3.1
Early Childhood Center	School Building	Staff Room	9545643	2020-12-07	Detector Kit	2.9
Early Childhood Center	School Building	Conference Room	9545644	2020-12-07	Detector Kit	2.2
Early Childhood Center	School Building	Kitchen	9545649	2020-12-07	Detector Kit	2.1
Early Childhood Center			9538506		Spike	33.7

- The EPA's recommended action level for radon is 4 pCi/L and will require mitigation by the district, followed by retesting.
- [1 number] of spike tests were conducted to ensure the integrity of the testing process and all spike tests passed satisfactorily.