

# Radon Testing Results - Suntex Elementary

## Action Level is 4.0 pCi/L

Site Name	Building Name	Room Description (per floor plan)	Kit serial #	Date Sampled	Type of test	Results (pCi/L)
Suntex Elementary	School House	Classroom 1a	9545331	12/07/20	Detector Kit	0.8
Suntex Elementary	School House	Classroom 1d	9545328	12/07/20	Duplicate	1.6
Suntex Elementary	School House	Classroom 2a	9545662	12/07/20	Detector Kit	1.1
Suntex Elementary	School House	Classroom 2d	9545601	12/07/20	Duplicate	1.7
Suntex Elementary	School House	Computer Area	9545409	12/07/20	Detector Kit	1.6
Suntex Elementary	Gym	Gym A	9545655	12/07/20	Detector Kit	2.0
Suntex Elementary	Gym	Gym B	9545656	12/07/20	Blank	< 0.3
Suntex Elementary	Gym	Gym C	9545332	12/07/20	Detector Kit	2.0
Suntex Elementary	Gym	Gym D	9545339	12/07/20	Duplicate	2.2
Suntex Elementary	Gym	Gym E	9545330	12/07/20	Detector Kit	1.6
Suntex Elementary	School House	Kitchen A	9545338	12/07/20	Detector Kit	1.4
Suntex Elementary	School House	KITCHEN B	9545337	12/07/20	Blank	< 0.3
Suntex Elementary	School House	LIBRARY	9545301	12/07/20	Detector Kit	1.3
			9538702		Spike	29.8

- The EPA's recommended action level for radon is 4 pCi/L and will require mitigation by the district, followed by retesting.
- [1 number] of spike tests were conducted to ensure the integrity of the testing process and all spike tests passed satisfactorily.

