

**WATER TESTING RESULTS – Harney ESD**  
Action Level is 15 parts per billion (ppb)

<b>FIXTURE LOCATION/DESCRIPTION</b>	<b>FIXTURE ID #</b>	<b>TEST DATE</b>	<b>TEST RESULT</b>
MENS RESTROOM LEFT SINK	20130000-006BF	3/23/2021	1.43 PPB
WOMENS RESTROOM RIGHT SINK	20130000-007BF	3/23/2021	0.206 PPB
DRINKING FOUNTAIN RIGHT	20310000-008DW	3/23/2021	0.17 PPB

**MRL = MINIMUM REPORTING LEVELS @ 0.103**  
**ND+ Non Detect – Lead Level is below the set detection limits of 0.103**